

Attachment 2

Classification	Safety Distance between Indoor Storage Place (for storage of organic peroxides , Type A and Type B self-reactive substances and mixtures of Class 5 public hazardous materials) and its Abutted Facilities (Unit: m)					
	Places Listed in Article 13.3, 13.4		Places Listed in Article 13.2		Places listed in Article 13.1	
	With Retaining Wall	Without Retaining Wall	With Retaining Wall	Without Retaining Wall	With Retaining Wall	Without Retaining Wall
$< CQ \times 10$	20m	40 m	30 m	50 m	50 m	60 m
$\geq CQ \times 10 < CQ \times 20$	22 m	45 m	33 m	55 m	54 m	65 m
$\geq CQ \times 20 < CQ \times 40$	24 m	50 m	36 m	60 m	58 m	70 m
$\geq CQ \times 40 < CQ \times 60$	27 m	55 m	39 m	65 m	62 m	75 m
$\geq CQ \times 60 < CQ \times 90$	32 m	65 m	45 m	75 m	70 m	85 m
$\geq CQ \times 90 < CQ \times 150$	37 m	75 m	51 m	85 m	79 m	95 m
$\geq CQ \times 150 < CQ \times 300$	42 m	85 m	57 m	95 m	87 m	105 m
$\geq CQ \times 300$	47 m	95 m	66 m	110 m	100 m	120 m

Note: CQ = Control Quantity