

Annexed 2 :

1. Violation of safety limits of technical specifications.
2. Any natural hazard or other conditions posed an actual threat to the safety of the nuclear reactor facility or significantly hampered site personnel in the

performance of duties necessary for safe operations of the nuclear reactor facility (such as fires, typhoons, floods, tsunamis, earthquakes, mob attacks, toxic gas leaks, release of radioactive materials, etc.)

3. (2) Any event that results in one of the following factors conditions that significantly compromises the ability capacity of the facility to mitigate the consequences of an accident :

(1) Loss of nuclear accident assessment capability, including loss of more than half of the safety system parameters displays or alarms in the main control room for more than fifteen minutes, and significantly affecting the judgement on the accident situation.

(2) Loss of nuclear accident emergency response related communication capabilities, including the simultaneous loss of the facility's dedicated emergency notification telephone to the competent authority and commercial wired telephone for more than one hour, or the loss of communication systems between emergency response organizations in the facility, and sufficiently to hinder the communication within the facility more than one hour.

4. Any operation or condition which is prohibited by the plant's Technical Specifications except when:

(1) The Technical Specification is administrative in nature. .

(2) The surveillance test was not performed within the time limit according to the technical specifications, and the following three conditions are met:

a. There are appropriate corrective actions.

b. The test has been completed.

c. Surveillance test results show that the system is functioning properly.

(3) The Technical Specification was revised prior to discovery of the event such that the operation or condition was no longer prohibited at the time of discovery of the event.

5. Any condition that results in significant degradation of the fission product barriers or the unit entered the unanalyzed condition and significantly compromises its safety.

6. Any event or condition that results in automatic or manual actuation of

engineered safety features except when:

- (1) A pre-planned sequence during testing or operation.
- (2) The actuation signal is confirmed to be a false signal or is not listed in the technical specifications and meets one of the following conditions s:
  - a. When it occurs, the system or equipment was removed from service beforehand.
  - b. The safety function of the system or equipment has been already completed.
  - c. The actuated systems are the reactor water cleanup system, or the ventilation system of the main control room, fuel building, auxiliary building, reactor building, and emergency cooling water system.

7. Except the pre-planned testing or repairing and approved by the competent authority, any event or condition that could have prevented the fulfillment of the safety function of structures or systems that are needed to perform the following functions:

- (1) Shut down the nuclear reactor and maintain it in a safe shutdown condition.
- (2) Remove residual heat from the nuclear reactor.
- (3) Control the release of radioactive materials.
- (4) Mitigate the consequences of an accident.

8. Conditions listed in the first paragraph of Article 13 of the Ionizing Radiation Protection Act.

9. One of the following conditions that related to the safety and health of the public and the plant personnel:

- (1) Violation of the provisions of the Ionizing Radiation Protection Act or the Nuclear Materials and Radioactive Waste Management Act to remove radioactive materials or radioactive waste from the facility.
- (2) Any event requiring the transport of a radioactively contaminated person to an offsite facility for medical treatment.
- (3) An accident occurs while the lifting nuclear fuel, radioactive waste, or nuclear reactor internal components inside the facility.
- (4) Nuclear fuel, radioactive source or radioactive waste is lost, stolen, or damaged.

10. Conditions listed in the Article 19 and Article 21 of the Operational Regulations Governing Nuclear Safeguards.
11. Security events related to intrusion or sabotage.