

Article 201 Type I, II or III fire suppression equipment shall be provided in places of obviously difficult-to-extinguish-fire in accordance with the table below:

Type of Place		Fire Suppression Equipment
Place for manufacturing and general processing of public hazard objects		Type I, II or III fire suppression equipment; however, Type I, II or III fire suppression equipment of the movable type shall not be used if the place has concerns of being filled with thick smoke.
Indoor Storage	One-story building with a height of 6m or more	Type II fire suppression equipment or Type III one other than the movable type
	Others	Outdoor hydrant for Type I fire suppression equipment, Type II fire suppression equipment, Type III movable foam equipment (only if outdoor foam hydrant is available) or Type III one other than the movable type
Outdoor storage		Type I, II or III fire suppression equipment; however, Type I, II or III fire suppression equipment of the movable type shall not be adopted if the place has concerns of being filled with thick smoke.
Indoor Storage Tank	For storing sulfur	Water mist Fire Extinguishing System of Type III Fire Suppression Equipment
	For storing Type IV public hazard objects with a flash point of 70°C or higher	Water mist Fire Extinguishing System; fixed type Foam Fire Extinguishing System; or CO ₂ , Inert Gas, Halocarbon or Dry Powder Fire Extinguishing System other than the movable type, in Type-III Fire Suppression Equipment
	Others	Fixed type Foam Fire Extinguishing System or CO ₂ , Inert Gas, Halocarbon or Dry Powder Fire Extinguishing System other than the movable type in Type-III Fire Suppression Equipment
Outdoor Storage Tank	For storing sulfur	Water mist Fire Extinguishing System of Type-III Fire Suppression Equipment
	For storing Type IV public hazard objects with a flash point of 70°C or higher	Water mist Fire Extinguishing System or fixed type Foam Fire Extinguishing System of Type-III Fire Suppression Equipment
	Others	Fixed type Foam Fire Extinguishing System of Type-III Fire Suppression Equipment
Indoor Gas Station		Fixed type Foam Fire Extinguishing System of Type-III Fire Suppression Equipment

Type IV and Type V fire-suppression equipment shall also be provided in above specified places with the following exceptions:

1. For places manufacturing or general processing of high flash point materials, Type IV fire-suppression equipment can be exempted within the effective range of a Type I, II or III fire-suppression equipment if the operating temperature is less than 100°C.
2. More than two sets of Type V fire-suppression equipment shall be equipped in places of outdoor or indoor storage tanks of Category IV public hazard objects.
3. Type V fire-suppression equipment shall be equipped in places of indoor gas stations.