

Attached Table 2:

Applicable area	Item	Limit	Remarks
Class B marine areas	pH	6.0–9.0	
	Biological oxygen demand (BOD)	150	
	Chemical oxygen demand (COD)	300	
	Suspended solids	150	
	Biological oxygen demand (BOD)	100	Applicable to newly-established enterprises or sewage systems for which project bid request procedures had not yet been completed as of October 20, 2017.
	Chemical oxygen demand (COD)	280	
	Suspended solids	100	
	Biological oxygen demand (BOD)	100	1. Enforced from July 1, 2018. 2. When a project or other improvement measure is involved, the enterprise or sewage systems shall submit an effluent pollutant reduction management plan by March 1, 2018, and shall implement the content of said plan after approval by the special municipality, county, or city competent authority; enforced from January 1, 2021.
	Chemical oxygen demand (COD)	280	
	Suspended solids	100	
	E. Coli	10,000,000	
	Oil and grease (n-hexane extract)	20	
	Anionic surfactants	1.0	
	Cyanide	1.0	
	Arsenic	3.0	
	Cadmium	0.5	
	Total chromium	2.0	
	Copper	2.0	
	Lead	5.0	
	Total mercury	0.10	
	Zinc	4.0	

	Nickel	1.0	
	Total residual chlorine	2.0	
	Water temperature	42	
	Benzene	0.05	
	Ethylbenzene	0.4	
	Dichloromethane	0.2	
	Chloroform	0.6	
	1,2-Dichloroethane	0.10	
	Chloroethene	0.10	
	Dimethyl phthalate (DMP)	0.2	
	Diethyl phthalate (DEP)	0.4	
	Dibutyl phthalate (DBP)	0.4	
	Benzyl butyl phthalate (BBP)	0.4	
	Di-n-octyl Phthalate (DNOP)	0.6	
	Di(2-ethylhexyl)phthalate (DEHP)	0.2	