

Appendix I

List of telecommunication room areas

Total number of pairs of recommended cable or communication volume (port)	Size of telecommunication room	Remark
Less than 200 and telecommunication room is required	2.6 m ² more than 2.6 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
201~600	7 m ² more than 7 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
601~1000	14 m ² more than 14 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
1001~2000	20 m ² more than 20 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
2001~4000	30 m ² more than 30 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
4001~6000	43 m ² more than 43 m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
More than 6001	Decided by telecommunication service provider, building constructor and owner of the building through negotiation	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m

