

Attachment 3

Classification	Width of Open Space to be Reserved (Unit: m)	
	With Retaining Wall	Without Retaining Wall
$< CQ \times 5$	≥ 3 m	≥ 10 m
$\geq CQ \times 5 < CQ \times 10$	≥ 5 m	≥ 15 m
$\geq CQ \times 10 < CQ \times 20$	≥ 6.5 m	≥ 20 m
$\geq CQ \times 20 < CQ \times 40$	≥ 8 m	≥ 25 m
$\geq CQ \times 40 < CQ \times 60$	≥ 10 m	≥ 30 m
$\geq CQ \times 60 < CQ \times 90$	≥ 11.5 m	≥ 35 m
$\geq CQ \times 90 < CQ \times 150$	≥ 13 m	≥ 40 m
$\geq CQ \times 150 < CQ \times 300$	≥ 15 m	≥ 45 m
$\geq CQ \times 300$	≥ 16.5 m	≥ 50 m

Note: CQ = Control Quantity