

Article 97-2 Halocarbon Clean Agent Fire Extinguishing Systems Theoretical extinguishing concentration and design concentration of Halocarbon Clean Agent Fire Extinguishing Systems shall comply with Article 83-1 provisions except that of Paragraph 2, Subparagraph 1, Item 2.

Maximum agent concentration of frequently occupied place shall comply with the following regulations

Agent Type	Design Concentration
HFC-23	30%
HFC-227ea	10.5%
FK-5-1-12	10%