

表二二二~一 厚金屬導線管之選定

| 線徑 | | 導線數 | | | | | | | | | |
|------------|------------------|--------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 單線 (公厘) | 絞線 (平方公 厘) | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| | | 導線管最小管徑 (公厘) | | | | | | | | | |
| 1.6 | | 16 | 16 | 16 | 16 | 22 | 22 | 22 | 28 | 28 | 28 |
| 2.0 | 3.5 | 16 | 16 | 16 | 22 | 22 | 22 | 28 | 28 | 28 | 28 |
| 2.6 | 5.5 | 16 | 16 | 22 | 22 | 28 | 28 | 28 | 36 | 36 | 36 |
| | 8 | 16 | 22 | 22 | 28 | 28 | 36 | 36 | 36 | 36 | 42 |
| | 14 | 16 | 22 | 28 | 28 | 36 | 36 | 36 | 42 | 42 | 54 |
| | 22 | 16 | 28 | 28 | 36 | 42 | 42 | 54 | 54 | 54 | 54 |
| | 30 | 16 | 36 | 36 | 36 | 42 | 54 | 54 | 54 | 70 | 70 |
| | 38 | 22 | 36 | 36 | 42 | 54 | 54 | 54 | 70 | 70 | 70 |
| | 50 | 22 | 36 | 42 | 54 | 54 | 70 | 70 | 70 | 70 | 82 |
| | 60 | 22 | 42 | 42 | 54 | 70 | 70 | 70 | 70 | 82 | 82 |
| | 80 | 28 | 42 | 54 | 54 | 70 | 70 | 82 | 82 | 82 | 92 |
| | 100 | 28 | 54 | 54 | 70 | 70 | 82 | 82 | 92 | 92 | 104 |
| | 125 | 36 | 54 | 70 | 70 | 82 | 82 | 92 | 104 | 104 | |
| | 150 | 36 | 70 | 70 | 82 | 82 | 92 | 104 | 104 | | |
| | 200 | 36 | 70 | 70 | 82 | 92 | 104 | | | | |
| | 250 | 42 | 82 | 82 | 92 | 104 | | | | | |
| | 325 | 54 | 82 | 92 | 104 | | | | | | |
| | 400 | 54 | 92 | 92 | | | | | | | |
| | 500 | 54 | 104 | 104 | | | | | | | |

註：1. 導線一條適用於設備接地導線及直流電路。
2. 厚金屬導線管之管徑根據 CNS 規定以內徑表示。