

表二二二～二 薄金屬導線管、無螺紋金屬導線管之選定

線 徑		導線數									
單線 (公厘)	絞線 (平方公厘)	1	2	3	4	5	6	7	8	9	10
		導線管最小管徑 (公厘)									
1.6		15	15	15	25	25	25	25	31	31	31
2.0	3.5	15	19	19	25	25	25	31	31	31	31
2.6	5.5	15	25	25	25	31	31	31	31	39	39
	8	15	25	25	31	31	39	39	39	51	51
	14	15	25	31	31	39	39	51	51	51	51
	22	19	31	31	39	51	51	51	51	63	63
	30	19	39	39	51	51	51	63	63	63	63
	38	25	39	39	51	51	63	63	63	63	75
	50	25	51	51	51	63	63	75	75	75	75
	60	25	51	51	63	63	75	75	75		
	80	31	51	51	63	75	75	75			
	100	31	63	63	75	75					
	125	39	63	63	75						
	150	39	63	75	75						
	200	51	75	75							
	250	51	75								
	325	51									
	400	51									
	500	63									

註：1. 導線一條適用於設備接地導線及直流電路。
 2. 薄金屬導線管、無螺紋金屬導線管之管徑根據 CNS 規定以內徑表示。