

Appendix I

List of telecommunication room areas

Total number of pairs of telephone cables to be introduced	Number of optical fiber cores at the subscriber side	Size of telecommunication room	Remark
200 pairs or fewer but must be installed in the telecommunication room	49-96	> 3.6 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 1.5 m
201~600 pairs	97-300	> 7 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 1.5 m
601~1000 pairs	301-600	> 14 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 2.5 m
1001~2000 pairs	601-1200	> 20 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 2.5 m
2001~4000 pairs	1201-2400	> 30 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 2.5 m
4001~6000 pairs	2401-4800	> 43 m ²	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 2.5 m
6001 pairs or more	4801 or more	To be decided by negotiation between builders and telecommunications enterprises or system operators that provide telecommunications service using fixed communication network architecture	Indoor net height at least 2.1 m; length of narrowest surface no shorter than 2.5 m